



cfo@vmc.gov.in



**FORM B 13.3**  
**FIRE SAFETY CERTIFICATE RENEWAL (FSCR)**  
(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOVMC/2021/00000102  
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOVMC/2021/00000102/R1

Date: 14/02/2025

Building Occupancy/Category: Educational (non-residential)

To,

SHAISHAV SCHOOL  
GOTRI ROAD GORTI VADODARA Vadodara MC 390021  
Fire Region: Vadodara MC  
Mobile No: 9825297761 Email ID: ndpatel.accordinfra@gmail.com

This has reference to your Application No. **2025/00104532** dated 13/01/2025 for **Fire Safety Certificate Renewal (FSCR)** for the building/premise **SHAISHAV SCHOOL (name of the Building/ Project)**, as per below mentioned details:

1. TP Number: 60
2. FP Number: 56/57
3. Survey Number: 59
4. Village Name: VADODARA
5. Name of Block(s): shaishav school

The building/premise was inspected on **14/02/2025** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on **14/02/2025**
2. Six monthly inspection was done on **14/02/2025**

The Fire Safety Certificate is renewed for a period of **two (2)** years upto **14/02/2027** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



**Digitally Verified**

Digitally verified by: Kantibhai Ashikbhai Patel  
Fire Safety Officer - Advance (FSO-A)  
2021/000232

Date: 14/02/2025  
Time: 12:26 PM



FSCA/O/CFOVMC/2021/00000102/R1

*This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at [www.gujfiresafetycop.in](http://www.gujfiresafetycop.in).*

*Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.*